

INVENTORY REFERENCE	COMPANY NAME	LOCATION	CONFIRMED PCB HOLDING	EQUIPMENT TYPE	EQUIPMENT QUANTITY	VOLUME	SMALL HOLDING	TRANSFORMERS	CAPACITORS	PFCU	OFCB	LIGHTS	OTHER	UPDATED BY	DATE UPDATED
PCB0001-24	Roadstone Ballintra	Donegal		Fluorescent Light Fittings	10	0.1	0.1					0.1		Notification	08.04.09
PCB0002-09	HSE - Bantry General Hospital	Cork		Fluorescent Light Fittings	20	0.2	0.2					0.2		Notification	17.12.07
PCB0002-10	HSE - Bunrana Nursing Home	Donegal		Fluorescent Light Fittings	92	0.92	0.92					0.92		Notification	25.01.08
PCB0002-11	HSE - Central Mental Hospital	Dublin		Fluorescent Light Fittings	216	2.16	2.16					2.16		Notification	17.12.07
PCB0002-12	HSE - Childrens University Hospital (Temple St.)	Dublin		Fluorescent Light Fittings	350	3.5	3.5					3.5		Notification	17.12.07
PCB0002-14	HSE - Community Hospital Youghal	Cork		Fluorescent Light Fittings	5	0.05	0.05					0.05		Notification	17.12.07
PCB0002-15	HSE - Donegal Community Hospital	Dublin		Fluorescent Light Fittings	10	0.1	0.1					0.1		Notification	25.01.08
PCB0002-17	HSE - Dungloe Community Hospital	Donegal		Fluorescent Light Fittings	110	1.1	1.1					1.1		Notification	25.01.08
PCB0002-18	HSE - Falcarragh Community Hospital	Donegal		Fluorescent Light Fittings	63	0.63	0.63					0.63		Notification	21.01.08
PCB0002-19	HSE - James Connolly Memorial Hospital	Donegal		Fluorescent Light Fittings	16	0.16	0.16					0.16		Notification	21.01.08
PCB0002-20	HSE - Letterkenny General Hospital	Donegal		Fluorescent Light Fittings	150	1.5	1.5					1.5		Notification	13.12.07
PCB0002-21	HSE - Lifford Community Hospital	Donegal		Fluorescent Light Fittings	25	0.25	0.25					0.25		Notification	25.01.08
PCB0002-22	HSE - Merlin Park Regional Hospital	Galway		Fluorescent Light Fittings	320	3.2	3.2					3.2		Notification	28.12.07
PCB0002-27	HSE - Northern Area Health Board (Rathdown Rd.)	Dublin		Fluorescent Light Fittings	50	0.5	0.5					0.5		Notification	13.02.08

PCB0002-28	HSE - Northern Area Health Board (Richmond Rd.)	Dublin		Fluorescent Light Fittings	50	0.5	0.5					0.5		Notification	13.02.08
PCB0002-29	HSE - Our Lady's Hospital	Leitrim		Fluorescent Light Fittings	50	0.5	0.5					0.5		Notification	11.01.08
PCB0002-30	HSE - Peamount Hospital	Dublin		Fluorescent Light Fittings	125	1.25	1.25					1.25		Notification	02.08.07
PCB0002-31	HSE - Ramelton Community Nursing Home	Donegal		Fluorescent Light Fittings	9	0.09	0.09					0.09		Notification	25.01.08
PCB0002-32	HSE - Rotunda Hospital	Dublin		Fluorescent Light Fittings	20	0.2	0.2					0.2		Notification	01.12.01
PCB0002-33	HSE - Sligo and Leitrim Mental Health Services	Sligo		Fluorescent Light Fittings	20	0.2	0.2					0.2		Notification	11.01.08
PCB0002-34	HSE - Sligo General Hospital	Sligo		Fluorescent Light Fittings	20	0.2	0.2					0.2		Notification	11.01.08
PCB0002-35	HSE - St. Clare's Home	Dublin		Fluorescent Light Fittings	50	0.5	0.5					0.5		Notification	20.02.08
PCB0002-36	HSE - St. Joseph's Hospital	Donegal		Fluorescent Light Fittings	40	0.4	0.4					0.4		Notification	25.01.08
PCB0002-37	HSE - St. Mary's Hospital	Dublin		Fluorescent Light Fittings	50	0.5	0.5					0.5		Notification	30.01.08
PCB0002-38	HSE - St. Patrick's Hospital (Phoenix Park)	Dublin		Fluorescent Light Fittings	150	1.5	1.5					1.5		Notification	11.01.08
PCB0002-39	HSE - St. Raphaels Centre	Cork		Fluorescent Light Fittings	116	1.16	1.16					1.16		Notification	17.12.07
PCB0002-40	HSE - St. Stephens Hospital (Glanmire)	Cork		Fluorescent Light Fittings	210	2.1	2.1					2.1		Notification	12.12.07
PCB0002-41	HSE - University College Hospital Galway	Galway		Fluorescent Light Fittings	420	4.2	4.2					4.2		Notification	18.02.08
PCB0004-06	Defence Forces - Engineer Platoon 2 LSB	Dublin		Fluorescent Light Fittings	50	0.5	0.5					0.5		Notification	28.11.07
PCB0007-06	Glanbia - Athy	Kildare		Capacitor*	1	2	2			2				Notification	06.11.07
PCB0011-02	Cavan Co. Co. - Bawnboy WWTP	Cavan		Fluorescent Light Fittings	6	0.06	0.06					0.06		Notification	21.12.07

PCB0011-03	Cavan Co. Co. - Belturbet WWTP	Cavan		Power Factor Correction Unit Fluorescent Light Fittings	1 11	1.8 0.11	1.8 0.11			1.8			0.11	Notification	21.12.07
PCB0011-04	Cavan Co. Co. - Cavan Regional WWTP (Clifferna)	Cavan		Power Factor Correction Unit Fluorescent Light Fittings	1 34	1.8 0.34	1.8 0.34			1.8			0.34	Notification	21.12.07
PCB0011-05	Cavan Co. Co. - Cavan Urban WTP (Keadeu)	Cavan		Fluorescent Light Fittings	14	0.14	0.14						0.14	Notification	21.12.07
PCB0011-06	Cavan Co. Co. - Cootehill WTP	Cavan		Power Factor Correction Unit Fluorescent Light Fittings	2 8	3.6 0.08	3.6 0.08			3.6			0.08	Notification	21.12.07
PCB0011-07	Cavan Co. Co. - Dowra WWTP	Cavan		Fluorescent Light Fittings	7	0.07	0.07						0.07	Notification	21.12.07
PCB0013-07	Wexford Co. Co. - Knockmullen WWTP	Wexford		Fluorescent Light Fittings	3	0.03	0.03						0.03	Notification	18.09.09
PCB00036-01	Henkel Loctite Limited - Tallaght	Dublin		Fluorescent Light Fittings	55	0.55	0.55						0.55	Notification	05.02.09
PCB0036-02	Henkel Loctite Limited - Ballyfermot	Dublin		Fluorescent Light Fittings	150	1.5	1.5						1.5	Notification	14.02.08
PCB0042-01	Irish Distillers Limited	Cork		Fluorescent Light Fittings	215	2.15	2.15						2.15	Notification	17.11.08
PCB0058-01	Paul & Vincent Limited	Longford		Fluorescent Light Fittings	30	0.3	0.3						0.3	Notification	02.12.08
PCB0075-01	Ames True Temper	Cork		Fluorescent Light Fittings	160	1.6	1.6						1.6	Notification	22.09.08
PCB0079-01	Arklow Harbour Commissioners	Wicklow		Fluorescent Light Fittings Flood Lighting*	3 2	0.03 4	0.03 4						0.03	Survey	22.10.09
PCB0084-01	Cara Partners Limited	Cork		Fluorescent Light Fittings	150	1.5	1.5						1.5	Notification	21.11.01
PCB0085-01	Castleknock College	Dublin		Fluorescent Light Fittings	230	2.3	2.3						2.3	Notification	01.12.01
PCB0087-01	Cognis Ireland Limited	Cork		Fluorescent Light Fittings	499	4.99	4.99						4.99	Notification	05.11.01
PCB0092-01	Cork City Co. - Lee Road WTW	Cork		Fluorescent Light Fittings	126	1.26	1.26						1.26	Notification	20.03.09
PCB0092-02	Cork City Co. - Churchfield Reservoir	Cork		Capacitor*	2	4	4		4					Notification	18.01.08

				Fluorescent Light Fittings	10	0.1	0.1					0.1			
PCB0096-01	Dalymount Park	Dublin		Floodlight controls*	4	4	4						4	Survey	01.10.09
PCB0098-01	Eli Lilly S.A.	Cork		Fluorescent Light Fittings	125	1.25	1.25					1.25		Notification	01.12.01
PCB0102-01	Greenisle Foods	Galway		Capacitor*	2	4	4			4				Notification	26.11.07
PCB0105-01	Heraeus Metal Processing Limited	Clare		Fluorescent Light Fittings	70	0.7	0.7					0.7		Notification	22.10.07
PCB0109-01	Janssen Pharmaceuticals Limited	Cork		Fluorescent Light Fittings	10	0.1	0.1					0.1		Notification	09.08.07
PCB0119-01	Novartis Agri Business Ireland	Waterford		Fluorescent Light Fittings	250	2.5	2.5					2.5		Notification	01.11.01
PCB0122-01	Pfizer Dun Laoghaire	Dublin		Fluorescent Light Fittings	100	1	1					1		Notification	26.11.07
PCB0127-01	Saint Gobain Performance Plastics	Clare		Fluorescent Light Fittings	20	0.2	0.2					0.2		Notification	22.10.07
PCB0129-01	SCI Ireland	Cork		Fluorescent Light Fittings	50	0.5	0.5					0.5		Notification	02.08.07
PCB0130-01	Smurfit Kappa Cork	Cork		Fluorescent Light Fittings	100	1	1					1		Notification	04.10.07
PCB0130-02	Smurfit Kappa Packaging Solutions	Dublin		Fluorescent Light Fittings	300	3	3					3		Notification	10.12.01
PCB0132-01	St. Davids CBS.	Dublin		Fluorescent Light Fittings	125	1.25	1.25					1.25		Notification	01.12.01
PCB0146-01	Galway Co. Co. - Clarinbridge WTW	Galway		Fluorescent Light Fittings	2	0.02	0.02					0.02		Notification	06.02.08
PCB0151-01	Leitrim Co. Co. - Rosebank WWTP	Leitrim		Power Factor Correction Unit Fluorescent Light Fittings	2 7	2.3 0.07	2.3 0.07			2.3		0.07		Notification	16.12.08
PCB0156-01	Mayo Co. Co. - Killybeg WWTP	Mayo		Fluorescent Light Fittings	80	0.8	0.8					0.8		Notification	15.11.01
PCB0156-02	Mayo Co. Co. - Turlough WWTP	Mayo		Fluorescent Light Fittings	60	0.6	0.6					0.6		Notification	19.11.01
PCB0159-03	Offaly Co. Co. - Lusmagh Booster	Offaly		Capacitor*	1	2	2			2				Notification	30.04.08
PCB0159-05	Offaly Co. Co. - Moyclare Source	Offaly		PFCU	1	2	2			2				Notification	30.04.08
PCB0159-06	Offaly Co. Co. - Birr Intake	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08

PCB0159-07	Offaly Co. Co. - Forest Borehole	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08
PCB0159-08	Offaly Co. Co. - Glebe Borehole	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08
PCB0159-09	Offaly Co. Co. - Ciara Hill Borehole	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08
PCB0159-10	Offaly Co. Co. - Clonaslee WTP	Offaly		Fluorescent Light Fittings	8	0.08	0.08					0.08		Notification	30.04.08
PCB0159-11	Offaly Co. Co. - Geashal WTW	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08
PCB0159-12	Offaly Co. Co. - Ardan Pumphouse	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08
PCB0159-13	Offaly Co. Co. - Clara WTW	Offaly		Fluorescent Light Fittings	66	0.66	0.66					0.66		Notification	30.04.08
PCB0159-14	Offaly Co. Co. - Kilcormac WWTP	Offaly		Fluorescent Light Fittings	2	0.02	0.02					0.02		Notification	30.04.08
PCB0159-15	Offaly Co. Co. - Cloneygown WWTP	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08
PCB0159-16	Offaly Co. Co. - Killagh WWTP	Offaly		Fluorescent Light Fittings	1	0.01	0.01					0.01		Notification	30.04.08
PCB0425-01	SAFC Arklow Limited	Wicklow		Fluorescent Light Fittings	10	0.1	0.1					0.1		Notification	10.12.08

**90.71**    90.71    0    12    11.5    0    59.21    8  
**Total:    90.71**

\* Indicates that the volume of oil has been estimated based on site information and/or the following

A capacitor and PFCU contains 2 litres of oil

An OFCB contains 20 litres of oil

A transformer contains 850 litres of oil

It is assumed that there is one ballast for every two fluorescent light units and each ballast is assumed to contain 0.02 litres of oil