

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Carlow County Council	Bagenalstown WSS	7,770	Supply identified by the HSE where further investigation or improvement maybe required
Carlow County Council	Ballinkillen	40	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Carlow County Council	Borris WSS	800	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Carlow County Council	Carlow Central Regional WSS	3,400	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Carlow County Council	Carlow Town WSS	13,215	Supply identified by the HSE where further investigation or improvement maybe required
Carlow County Council	Hacketstown	733	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cavan County Council	Arvagh PWS	525	EPA Audit Observation - Treatment and Management Issues
Cavan County Council	Ballinagh P.W.S.	840	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Cavan County Council	Ballyconnell	956	Supply identified by the HSE where further investigation or improvement maybe required
Cavan County Council	Belturbet	1,610	Supply identified by the HSE where further investigation or improvement maybe required
Cavan County Council	Cavan R.W.S.S.	7,525	Elevated levels of THMs above the standard in the Drinking Water Regulations
Cavan County Council	Cootehill	2,000	Supply identified by the HSE where further investigation or improvement maybe required
Cavan County Council	Dowra P.W.S.	228	Excessive levels of aluminium in the treated water
Cavan County Council	Killeshandra P.W.S.	683	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Cavan County Council	Kingscourt	1,925	Supply identified by the HSE where further investigation or improvement maybe required
Clare County Council	Ardataggle PWS	275	Elevated levels of THMs above the standard in the Drinking Water Regulations
Clare County Council	Ballyvaughan	1,000	Supply identified by the HSE where further investigation or improvement maybe required
Clare County Council	Broadford	350	Supply identified by the HSE where further investigation or improvement maybe required
Clare County Council	Ennis PWS	23,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Clare County Council	Ennistymon RWS	8,220	Elevated levels of THMs above the standard in the Drinking Water Regulations
Clare County Council	Flagmount PWS	100	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Clare County Council	Shannon/Sixmilebridge RWSS	16,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Clare County Council	Turlough PWS	500	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Cork (North) County Council	Bartlemy	100	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (North) County Council	Burnfort	100	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (North) County Council	Doneraile	3,000	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (North) County Council	Labbamolloga	40	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (North) County Council	Millstreet	2,000	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (North) County Council	Mount North	1,000	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (North) County Council	Rahan	350	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (South) County Council	Ballincurragh/Lisgoold	300	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (South) County Council	Ballingeary	500	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (South) County Council	Ballymakerra	400	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Cork (South) County Council	Bilberry	40	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (South) County Council	Clash/Leamleara	80	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (South) County Council	Donoughmore	250	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Cork (South) County Council	Kilbritten	250	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (South) County Council	Roberts Cove	300	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Cork (South) County Council	Walshstown Beg	50	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (South) County Council	Youghal Regional	6,000	Excessive levels of aluminium in the treated water
Cork (West) County Council	Ballineen	500	Inadequate treatment for Cryptosporidium
Cork (West) County Council	Bantry Old	600	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Cahermore	80	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Castletownbere New	2,500	Inadequate treatment for Cryptosporidium
Cork (West) County Council	Castletownbere Old	400	Inadequate treatment for Cryptosporidium
Cork (West) County Council	Castletownkinnagh	50	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Cork (West) County Council	Clonakilty	10,000	Excessive levels of aluminium in the treated water
Cork (West) County Council	Coppeen No.2	30	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Crossterra	50	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Drimoleague	400	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Dromore public (Bantry)	50	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Durseys Island	10	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Johnstown	15	Inadequate treatment - no disinfection
Cork (West) County Council	Kealkill	150	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Cork (West) County Council	Leap	1,500	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Schull	2,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Cork (West) County Council	Skibbereen	4,524	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Snave	100	Inadequate treatment for Cryptosporidium
Cork (West) County Council	Tarelton	25	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork (West) County Council	Whiddy Island	30	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Cork City Council	Cork City Water Supply	123,000	EPA Audit Observation - Treatment and Management Issues
Donegal County Council	Ballintra	450	Elevated levels of THMs above the standard in the Drinking Water Regulations
Donegal County Council	Ballyshannon	5,000	Poor turbidity removal
Donegal County Council	Burnfoot	1,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Donegal County Council	Carrick-Teelin	780	Poor turbidity removal
Donegal County Council	Carrigar-Downings	1,400	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Cashilard	400	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Cresslough	4000	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Donegal County Council	Fanad West (Tullyconnell)	500	Poor turbidity removal
Donegal County Council	Frosses-Inver	2,000	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Glenties-Ardara	4,500	Inadequate treatment for Cryptosporidium
Donegal County Council	Gortahork-Falcarragh	5,000	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Greencastle	807	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Inishowen West	7,000	Poor turbidity removal
Donegal County Council	Kilcar	300	Poor turbidity removal
Donegal County Council	Killybegs	5,000	Excessive levels of aluminium in the treated water
Donegal County Council	Letterkenny	19,500	Inadequate treatment for Cryptosporidium
Donegal County Council	Lifford (Old)	36	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Donegal County Council	Lough Mourne	17,000	Elevated levels of THMs above the standard in the Drinking Water Regulations

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Donegal County Council	Malinmore	500	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Pettigo	510	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Donegal County Council	Portnoo-Narin	656	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Rathmullen	2,050	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Donegal County Council	Rosbeg	285	Inadequate treatment for Cryptosporidium
Donegal County Council	Rosses Regional	10,000	Poor turbidity removal
Dublin City Council	Ballyboden	37500	EPA Audit Observation - Treatment and Management Issues
Galway County Council	Ahascaragh PS	1,400	Inadequate treatment for Cryptosporidium
Galway County Council	Ballinasloe Rws	6,562	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Ballyconneely P.S.	931	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Ballygar	1,000	Inadequate treatment for Cryptosporidium
Galway County Council	Ballymoe	670	Inadequate treatment for Cryptosporidium
Galway County Council	Carraroe PWS	3,875	Inadequate treatment for Cryptosporidium
Galway County Council	Clarinbridge/Kilcolgan RWSS	1,270	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Galway County Council	Cleggan/Claddaghduff	1,025	Inadequate treatment for Cryptosporidium
Galway County Council	Clifden	3,180	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Clonbur PS	350	Poor turbidity removal
Galway County Council	Cornamona P.S.	240	Inadequate treatment for Cryptosporidium
Galway County Council	Derryinver P.S.	108	Inadequate treatment for Cryptosporidium
Galway County Council	Derryrush P.S.	300	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Galway County Council	Dunmore/Glenamaddy P.S.	1,185	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Eyrecourt	290	Inadequate treatment for Cryptosporidium
Galway County Council	Glenamaddy	900	Poor turbidity removal
Galway County Council	Gort	4,775	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Inisboffin P.S.	486	Inadequate treatment for Cryptosporidium
Galway County Council	Inishere P.S.	274	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Inishmore	2,725	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Galway County Council	Kilconell PWS	200	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Galway County Council	Killimor PWS	500	Elevated levels of THMs above the standard in the Drinking Water Regulations

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Galway County Council	Kinvara P.S.	605	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Leenane P.S.	100	Inadequate treatment for Cryptosporidium
Galway County Council	Letterfrack PWS(Dawros)	300	Inadequate treatment for Cryptosporidium
Galway County Council	Loughrea Public Supply	3,643	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Mid Galway	2,083	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Galway County Council	Mountbellew P.S.	1,076	Poor turbidity removal
Galway County Council	Oughterard	1,660	Excessive levels of aluminium in the treated water
Galway County Council	Portumna PS	1,228	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Galway County Council	Rosmuc P.S	1,090	Inadequate treatment for Cryptosporidium
Galway County Council	Roundstone P.S	1,815	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Spiddal Public Water Supply	739	Elevated levels of THMs above the standard in the Drinking Water Regulations
Galway County Council	Teeranea/Lettermore P.S.	2,725	Inadequate treatment for Cryptosporidium
Galway County Council	Tully-Tullycross	325	Inadequate treatment for Cryptosporidium
Galway County Council	Williamstown PS	180	Poor turbidity removal
Galway County Council	Woodford	400	Inadequate Treatment
Kerry County Council	Anascaul 002D	450	Poor turbidity removal
Kerry County Council	Ardfert North 003E	1,558	Poor turbidity removal
Kerry County Council	Aughacaslá 005D	492	Inadequate treatment for Cryptosporidium
Kerry County Council	Báile Breach 092D	140	Inadequate treatment for Cryptosporidium
Kerry County Council	Ballinskelligs 008H	901	Inadequate treatment for Cryptosporidium
Kerry County Council	Ballymacadam 402F	4,132	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kerry County Council	Ballymore	981	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Kerry County Council	Barraduff 602E	406	Inadequate treatment for Cryptosporidium
Kerry County Council	Breanlee 088A	752	Inadequate treatment for Cryptosporidium
Kerry County Council	Caherdaniel 019H	364	Inadequate treatment for Cryptosporidium
Kerry County Council	Cahirciveen 017H	1,725	Poor turbidity removal
Kerry County Council	Camp 020D	731	Inadequate treatment for Cryptosporidium
Kerry County Council	Caragh Lake 022A	1,757	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Kerry County Council	Castlecove 023H	353	Inadequate treatment for Cryptosporidium

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Kerry County Council	Castlegregory 024D	1,148	Inadequate treatment for Cryptosporidium
Kerry County Council	Dingle 030D	3,784	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kerry County Council	Emlaghpeasta 035H	178	Inadequate treatment for Cryptosporidium
Kerry County Council	Feoghanagh 038D	243	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Kerry County Council	Glen 039H	59	Inadequate treatment for Cryptosporidium
Kerry County Council	Glenbeigh 040A	41	Inadequate treatment for Cryptosporidium
Kerry County Council	Inch Pws 044D	504	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Kerry County Council	Kenmare 045A	1,832	Inadequate treatment for Cryptosporidium
Kerry County Council	Kilgarvan 046A	327	Inadequate treatment for Cryptosporidium
Kerry County Council	Killsarkin 403F	1,363	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kerry County Council	Lauragh 051A	75	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Kerry County Council	Lisarboola 404F	13,820	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kerry County Council	Liscarney 052D	24	Inadequate treatment for Cryptosporidium
Kerry County Council	Lough Guitane 400F	55,848	Inadequate treatment for Cryptosporidium
Kerry County Council	Lyre 057E	1,117	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kerry County Council	Mid Kerry/Gearha (H) 300A	9,400	Inadequate treatment for Cryptosporidium
Kerry County Council	Minard No. 2 061D	174	Poor turbidity removal
Kerry County Council	Minard No. 3 090D	189	Inadequate treatment for Cryptosporidium
Kerry County Council	Mountain Stage 062A	1,017	Inadequate treatment for Cryptosporidium
Kerry County Council	Murreigh Ballydavid 063D	450	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Kerry County Council	Rathmore 065A	797	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kerry County Council	Scartleigh(H) 600E	0	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kerry County Council	Shrone 078A	199	Inadequate treatment for Cryptosporidium
Kerry County Council	Sneem 068A	447	Inadequate treatment for Cryptosporidium
Kerry County Council	Templenoe 073A	207	Poor turbidity removal
Kerry County Council	Tieraclea (Tarbert) PWSS	528	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Kerry County Council	Ventry 074D	500	Inadequate treatment for Cryptosporidium
Kerry County Council	Waterville 075H	842	Poor turbidity removal
Kilkenny County Council	Ballyragget WS	1,103	Elevated levels of Nitrate above the standard in the Drinking Water Regulations

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Kilkenny County Council	Bennettsbridge Regional WS	3,500	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Kilkenny County Council	Clogh-Castlecomer WS	2,640	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kilkenny County Council	Inistioge WS	986	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kilkenny County Council	Kilkenny City (Radestown) WS	8,625	Elevated levels of THMs above the standard in the Drinking Water Regulations
Kilkenny County Council	Kilkenny City (Troyswood) WS	11,521	Excessive levels of aluminium in the treated water
Kilkenny County Council	Mooncoin Regional WS	7,148	Excessive levels of aluminium in the treated water
Kilkenny County Council	Paulstown PWS	2,000	Inadequate treatment for Cryptosporidium
Kilkenny County Council	Urlingford-Johnstown	1,437	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Laois County Council	Ballinakill 2 PWS	400	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Laois County Council	Clonaslee PWS	1,304	Excessive levels of aluminium in the treated water
Laois County Council	Durrow 1 PWS	774	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Laois County Council	Mountmellick 1 PWS	5,268	Elevated levels of THMs above the standard in the Drinking Water Regulations
Leitrim County Council	Fivemilebourne	120	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Leitrim County Council	South Leitrim Regional	11,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Limerick City Council	Limerick City Council Drinking Water	52,000	Excessive levels of aluminium in the treated water
Limerick County Council	Ballingarry	562	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Limerick County Council	Ballyhahill Pub DWS	260	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Limerick County Council	Banogue Pub DWS	100	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Limerick County Council	Caherconlish PWS	1601	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Limerick County Council	Caherdavid Pub DWS	1,567	Excessive levels of aluminium in the treated water
Limerick County Council	Castleconnell Pub DWS	1,567	Elevated levels of THMs above the standard in the Drinking Water Regulations
Limerick County Council	Castletroy Pub DWS	11,343	Excessive levels of aluminium in the treated water
Limerick County Council	Faleen Pub DWS	1,352	Poor turbidity removal

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Limerick County Council	Foynes / Shannon Estuary Pub DWS	1,481	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Limerick County Council	Kilbehenny PWS	160	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Limerick County Council	Kilmallock Pub DWS	2,338	Poor turbidity removal
Limerick County Council	Mungret / Clarina Pub DWS	691	Elevated levels of THMs above the standard in the Drinking Water Regulations
Limerick County Council	Oola Pub DWS	1,152	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Limerick County Council	Pallaskenry/Kildimo Pub DWS	775	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Limerick County Council	Raheen / Lisnalty Pub DWS	4,395	Elevated levels of THMs above the standard in the Drinking Water Regulations
Limerick County Council	Rockhill	340	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Longford County Council	Granard	1,915	Excessive levels of aluminium in the treated water
Longford County Council	Longford Central	8,717	Excessive levels of aluminium in the treated water
Louth County Council	Ardee	6,500	Excessive levels of aluminium in the treated water
Louth County Council	Omeath	300	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Louth County Council	Staleen	25,000	Poor turbidity removal
Mayo County Council	Achill Regional PS	3,774	Supply identified by the HSE where further investigation or improvement maybe required
Mayo County Council	Ballyhaunis	3,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Mayo County Council	Clare Island	180	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Mayo County Council	Cong	700	Inadequate treatment for Cryptosporidium
Mayo County Council	Foxford	900	Elevated levels of THMs above the standard in the Drinking Water Regulations
Mayo County Council	Inishturk	50	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Mayo County Council	Kilmaine PS	607	Supply identified by the HSE where further investigation or improvement maybe required

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Mayo County Council	Kiltimagh	1,239	Elevated levels of THMs above the standard in the Drinking Water Regulations
Mayo County Council	Lough Mask	28,156	Elevated levels of THMs above the standard in the Drinking Water Regulations
Mayo County Council	Louisburg	500	Excessive levels of aluminium in the treated water
Mayo County Council	Mulranny	781	Excessive levels of aluminium in the treated water
Mayo County Council	Newport PWS	274	Supply identified by the HSE where further investigation or improvement maybe required
Mayo County Council	Swinford	2,000	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Mayo County Council	Westport	6,730	Excessive levels of aluminium in the treated water
Meath County Council	Ballinaclose	200	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Meath County Council	Ballivor	1,280	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Meath County Council	Carrickleck	42	Inadequate treatment - no disinfection
Meath County Council	Castletown	150	Inadequate treatment - no disinfection
Meath County Council	East Meath	30,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Meath County Council	Kells-Oldcastle	8,250	Inadequate treatment for Cryptosporidium
Meath County Council	Lobinstown	60	Inadequate treatment - no disinfection
Meath County Council	Navan & MidMeath PWS	28,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Meath County Council	Trim PWS	8,850	Elevated levels of THMs above the standard in the Drinking Water Regulations
Monaghan County Council	Carrickmacross	3,341	Supply identified by the HSE where further investigation or improvement maybe required
Monaghan County Council	Clones	2,800	Excessive levels of aluminium in the treated water
Monaghan County Council	Lough Egish RWSS	6,100	Elevated levels of THMs above the standard in the Drinking Water Regulations
Monaghan County Council	Monaghan	7,500	Excessive levels of aluminium in the treated water
North Tipperary County Council	Cloughjordan	907	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
North Tipperary County Council	Lorrha/Riverstown	640	Inadequate treatment for Cryptosporidium
North Tipperary County Council	Nenagh RWSS (Zone 1)	11,823	Elevated levels of THMs above the standard in the Drinking Water Regulations
North Tipperary County Council	Thurles (Zone 2)	175	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
North Tipperary County Council	Toomevara	553	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
North Tipperary County Council	Two Mile Borris	627	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
North Tipperary County Council	Ballinarry/Eglis	378	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Offaly County Council	Birr P.W.S.	3,912	Excessive levels of aluminium in the treated water
Offaly County Council	Clara/Ferbane RWSS P.W.S.	5,000	Elevated levels of THMs above the standard in the Drinking Water Regulations
Offaly County Council	Dungar P.W.S.	135	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Offaly County Council	Tullamore P.W.S.	10,000	Excessive levels of aluminium in the treated water
Roscommon County Council	Arigna	270	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Roscommon County Council	Ballinlough/Loughglynn	2500	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Roscommon County Council	Ballyfarnan	200	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Roscommon County Council	Ballyleague	700	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Roscommon County Council	Bellanagare	250	EPA Audit Observation - Treatment and Management Issues
Roscommon County Council	Boyle/Ardcarne	1,200	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Roscommon County Council	Castlerea Regional	2,600	Inadequate treatment for Cryptosporidium
Roscommon County Council	Castlerea Urban	1,800	Poor turbidity removal
Roscommon County Council	Grangemore	700	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Roscommon County Council	Keadue	180	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Roscommon County Council	Leacarrow	600	Inadequate treatment for Cryptosporidium
Roscommon County Council	Mount Talbot	3500	Inadequate treatment for Cryptosporidium
Roscommon County Council	North East RWSS	4,800	Inadequate treatment for Cryptosporidium

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Roscommon County Council	North Roscommon Regional Water Supply Scheme	5,750	Elevated levels of THMs above the standard in the Drinking Water Regulations
Sligo County Council	Killaraght Public Water Supply	110	Elevated levels of THMs above the standard in the Drinking Water Regulations
Sligo County Council	Kilsellagh	11,220	Inadequate treatment for Cryptosporidium
Sligo County Council	Lough Easkey Regional Water Supply	4,500	Excessive levels of aluminium in the treated water
Sligo County Council	Lough Talt Regional Water Supply	9,250	Inadequate treatment for Cryptosporidium
Sligo County Council	North Sligo Regional Water Supply	2,400	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Sligo County Council	South Sligo Regional Water Supply	592	Elevated levels of THMs above the standard in the Drinking Water Regulations
South Tipperary County Council	Ardfinnan Regional	8,250	Excessive levels of aluminium in the treated water
South Tipperary County Council	Ballincurry	500	Inadequate treatment for Cryptosporidium
South Tipperary County Council	Burncourt	2,038	Inadequate treatment for Cryptosporidium
South Tipperary County Council	Cahir Reservoir	500	Inadequate treatment for Cryptosporidium
South Tipperary County Council	Carrick-on-Suir (Crotty's Lake)	2,500	Inadequate treatment for Cryptosporidium
South Tipperary County Council	Carrick-on-Suir [Lingaun River]	3,000	Excessive levels of aluminium in the treated water
South Tipperary County Council	Clonmel Poulavanogue	5000	Inadequate treatment for Cryptosporidium
South Tipperary County Council	Cloran Regional	2,500	Inadequate treatment for Cryptosporidium
South Tipperary County Council	Dundrum Regional	4,783	Excessive levels of aluminium in the treated water
South Tipperary County Council	Galtee Regional	11,600	Excessive levels of aluminium in the treated water
South Tipperary County Council	Gortnapisha	2,500	Inadequate treatment for Cryptosporidium

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
South Tipperary County Council	Graigue	1,192	Inadequate treatment for Cryptosporidium
South Tipperary County Council	Mullenbawn	2,500	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
South Tipperary County Council	Tipperary UDC	5,209	Inadequate treatment for Cryptosporidium
Waterford City Council	East Waterford Regional	41,945	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Adramone	19	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Waterford County Council	Ardmore	1,380	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Ballinacourty/Deelish	1,500	Poor turbidity removal
Waterford County Council	Ballyduff/Ballylemon	650	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Ballyhane	1,000	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Waterford County Council	Ballyshunnock	10	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Cappoquin	1,300	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Waterford County Council	Castlereagh	18	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Colligan	60	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Croan Upper	14	Inadequate treatment for Cryptosporidium
Waterford County Council	Geoish	55	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Waterford County Council	Glenegad/Scrothea	10	Elevated levels of Bromate above the standard in the Drinking Water Regulations
Waterford County Council	Graiguenageeha	40	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Inchinleamy	100	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Waterford County Council	Kilgaineey	60	Elevated levels of THMs above the standard in the Drinking Water Regulations
Waterford County Council	Kilmacomma	240	Inadequate treatment for Cryptosporidium
Waterford County Council	Kilmore-Kilbeg	20	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Waterford County Council	Kilnafrehan	30	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Kilnamack	30	Inadequate treatment for Cryptosporidium
Waterford County Council	LCB Lismore, Cappoquin, Ballyduff	4,532	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Waterford County Council	Rathgormuck	127	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Ring/Helvick	1,100	Elevated levels of THMs above the standard in the Drinking Water Regulations
Waterford County Council	Shanacoole	100	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Waterford County Council	Shekskin	100	Inadequate treatment for Cryptosporidium
Waterford County Council	Smoorebeg	40	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Stradbally	500	Excessive levels of aluminium in the treated water
Waterford County Council	Tallow	1,164	Elevated levels of THMs above the standard in the Drinking Water Regulations
Waterford County Council	Tinkock/Tinnabinna	112	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Waterford County Council	Tallow Hill	120	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Wexford County Council	Gorey Region	13,630	Elevated levels of THMs above the standard in the Drinking Water Regulations
Wexford County Council	Kiltealy	250	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Wexford County Council	Taghmon	850	Excessive levels of aluminium in the treated water
Wicklow County Council	Arklow Public Supply	10,000	Supply identified by the HSE where further investigation or improvement maybe required
Wicklow County Council	Aughrim / Annacurra	950	Supply identified by the HSE where further investigation or improvement maybe required
Wicklow County Council	Avoca / Ballinclash Public Supply	950	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.

Local Authority	Name of Water Supply	Population Served	Primary Cause of Concern <i>(there may be other issues than those listed)</i>
Wicklow County Council	Ballynavortha	12	Elevated levels of Nitrate above the standard in the Drinking Water Regulations
Wicklow County Council	Blessington Public Supply	2,509	Elevated levels of THMs above the standard in the Drinking Water Regulations
Wicklow County Council	Enniskerry Public Supply	1,500	Excessive levels of aluminium in the treated water
Wicklow County Council	Glenealy Public Supply	360	Elevated levels of THMs above the standard in the Drinking Water Regulations
Wicklow County Council	Laragh / Annamoe Public Supply	815	Supply identified by the HSE where further investigation or improvement maybe required
Wicklow County Council	Rathdrum	1,500	Inadequate treatment for Cryptosporidium
Wicklow County Council	Redcross	400	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.
Wicklow County Council	Stratford	380	Inadequate treatment for Cryptosporidium
Wicklow County Council	Wicklow Regional Public Supply	12,152	Elevated levels of THMs above the standard in the Drinking Water Regulations
Wicklow County Council	Windgates/Templecarrig	300	Failed to meet E.coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified.