



Environmental Protection Agency
An Ghníomhaireacht um Chaomhú na n-Éilimh

Mr. Gerry Boyle
Senior Engineer
Meath County Council
County Hall
Railway Street
Navan
County Meath

Headquarters, PO Box 3000
Johnstown Castle Estate
County Wexford, Ireland
Ceannteachtú, Bosca Poist 3000
Eastát Chaisleán Bhaile Sheáin
Contae Loch Garman, Éire

T: +353 53 916 0600
F: +353 53 916 0699
E: info@epa.ie
W: www.epa.ie
LoCall: 1890 33 55 99

07 April 2010

re: Notice in accordance with Regulation 25(c)(ii) of the Waste Water Discharge (Authorisation) Regulations 2007

Dear Mr. Boyle

I am to refer to the applications for a waste water discharge certificate of authorisation relating to the agglomerations named:

Robinstown	A0016-01	Carnaross	A0043-01
Ardcath	A0017-01	Castletown	A0044-01
Clonalvy	A0018-01	Hill of Tara	A0048-01
Dunderry	A0019-01	Lobinstown	A0052-01
Kilberry	A0021-01	Lloyd Kells	A0053-01
Cortown	A0023-01	Skreen	A0055-01
Bohermeen	A0028-01	Ballinabrackey	A0062-01
Bellewstown	A0041-01	Batterstown	A0063-01

Having examined the documentation submitted, I am to advise that the Agency is of the view that the documentation, for each application above, does not comply with Regulation 24 of the Waste Water Discharge (Authorisation) Regulations 2007.

You are therefore requested, in accordance with Regulation 25(c)(ii) of the regulations, for each application above, to take the steps to supply the information detailed below:

- Assess the likelihood of significant effects of the waste water discharges from the above agglomerations on the relevant European sites by referring to Circular L8/08 'Water Services Investment and Rural Water Programmes – Protection of Natural Heritage and National Monuments' issued by the Department of Environment, Heritage and Local Government. In particular, the flow diagram in Appendix 1 should be completed and the results of each section recorded. Provide details of the results of this assessment within one month of the date of this notice. If significant effects are likely then an appropriate assessment must be carried out and a report of this assessment forwarded to the Agency within one month of the date of this notice.

You are advised to provide the requested information in accordance with the 'Note on Appropriate Assessments for the purposes of the Waste Water Discharge (Authorisation) Regulations, 2007 (S.I. 684 of 2007)' which is available at www.epa.ie/downloads/forms/lic/wwda/


Your reply to this notice should include a revised non-technical summary which reflects the information you supply in compliance with the notice, insofar as that information impinges on the non-technical summary.

In the case where any drawings already submitted are subject to revision consequent on this request, a revised drawing should be prepared in each case. It is not sufficient to annotate the original drawing with a textual correction. Where such revised drawings are submitted, provide a list of drawing titles, drawing numbers and revision status, which correlates the revised drawings with the superseded versions.

Please supply the information in the form of a one original plus one copy within **1 month** of the date of this notice. In addition please submit one copy of the requested information in electronic searchable PDF format on a CD-ROM (no file to exceed 10MB) to the Agency. Please note that all maps/drawings should not exceed A3 in size.

Please direct all correspondence in relation to this matter to *Administration, Environmental Licensing Programme, Office of Climate, Licensing & Resource Use, Environmental Protection Agency, Headquarters, PO Box 3000, Johnstown Castle Estate, County Wexford* quoting the register number.

Yours sincerely,



Dr. Karen Creed
Senior Inspector
Office of Climate, Licensing & Resource Use