





County	Name of Water Supply	Scheme Code	Population Served	Volume Supplied (m3/day)	RAL Heading	Proposed Action Programme	Interim Measures	Proposed Date of Completion of Action Programme	Date Complete (if awaiting verification of the effectiveness)	Inadequate Treatment for Cryptosporidium	Inadequate Treatment - Inadequate Disinfection	Failed to meet E coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified	Elevated Levels of THMs above the standard in the Drinking Water Regulations	Elevated Levels of Pesticides above the standard in the Drinking Water Regulations	Supply identified by the HSE where further investigation or improvement may be required	Excessive levels of aluminium in the treated water	Poor turbidity removal	EPA Audit Observation - Treatment and Management Issues
Tipperary	Graigie	2900PUB0205	1,613	1,350	Inadequate treatment for Cryptosporidium	Abandon water treatment plant and replace with new source	Installation of turbidity and chlorine monitors	Complete but need verification of the effectiveness of the action plan		Y								
Tipperary	Mullenbawn	2900PUB0149	1,612	1,542	Failed to meet E coli/Enterococci standard as reported in the Drinking Water Report and needs investigation and improvement if necessary to ensure that the root cause of the problem has been rectified	Upgrade of water treatment plant		Sep-17				Y						
Waterford	Lismore	3100PUB1138	248	458	Elevated levels of THMs above the standard in the Drinking Water Regulations	Upgrade of water treatment plant		Mar-18					Y					
Waterford	Ring/Helvic	3100PUB1084	870	233	Elevated levels of THMs above the standard in the Drinking Water Regulations	Abandon source of water supply and replace with Dungarvan PWS	Optimise disinfection process. Unidirectional Flushing Programme.	Jun-19	Direction requires the completion of the remedial work by December 2018				Y					
Waterford	Stradbally	3100PUB1093	566	242	Excessive levels of aluminium in the treated water	Upgrade of water treatment plant		Oct-17								Y		
Wexford	Sow Regional	3300PUB1641	11,144	3,097	Inadequate treatment - inadequate disinfection	Upgrade of water treatment plant	N/A	Sep-17	Dec-14		Y							
Wicklow	Aughim / Annacurra	3400PUB1023	1,588	285	Supply identified by the HSE where further investigation or improvement maybe required	Abandon source of the water supply and replace with the Vartry Reservoir PWS	Optimisation of the disinfection system	Dec-20					Y		Y			
Wicklow	Avoca / Ballinlash Public Supply	3400PUB1024	1,386	290	Elevated levels of THMs above the standard in the Drinking Water Regulations	Upgrade of water treatment plant		Complete but need verification of the effectiveness of the action plan					Y					
Wicklow	Enniskerry Public Supply	3400PUB1019	2,743	622	Elevated levels of THMs above the standard in the Drinking Water Regulations	Replacement of Callow Hill Tunnel and upgrade of water treatment plant		Dec-20					Y					
Wicklow	Wicklow Regional Public Supply	3400PUB1005	16,484	2,840	Elevated levels of THMs above the standard in the Drinking Water Regulations	Treatment plant to be upgraded to improve chemical dosing system amid improved management of distribution network.	Optimisation of the disinfection system	Dec-20					Y					
Wicklow	Bray	3400PUB1001	29,617	9,222	EPA Audit Observation - Treatment and Management Issues	Replacement of Callow Hill Tunnel and upgrade of water treatment plant		Dec-20					Y					Y
Wicklow	Greystones/Windgates/Templecarraig	3400PUB1003	16,288	3,593	EPA Audit Observation - Treatment and Management Issues	Replacement of Callow Hill Tunnel and upgrade of water treatment plant		Dec-20					Y					Y
Wicklow	Kilmacanogue	3400PUB1009	1,392	201	EPA Audit Observation - Treatment and Management Issues	Replacement of Callow Hill Tunnel and upgrade of water treatment plant		Dec-20					Y					Y
Wicklow	Newtown Newcastle Kilcoole	3400PUB1010	12,175	1,680	EPA Audit Observation - Treatment and Management Issues	Replacement of Callow Hill Tunnel and upgrade of water treatment plant		Dec-20					Y					Y