

County	Name of Water Supply	Scheme Code	Population Served	Volume Supplied (m3/day)	Proposed Action Programme	Proposed Date of Completion of Action Programme (This is the date by which works are complete. There will be a further 3 month period to demonstrate the effectiveness of works before the supply is removed from the RAL.)	RAL Category								
							Inadequate Treatment for Cryptosporidium	Inadequate Treatment - Inadequate Disinfection	Failed to meet E coli/Enterococci standard in the Drinking Water Regulations	Elevated Levels of THMs above the standard in the Drinking Water Regulations	Elevated Levels of Pesticides above the standard in the Drinking Water Regulations	Supply identified by the HSE where further investigation or improvement may be required	Excessive levels of aluminium in the treated water	Poor turbidity removal	EPA Audit Observation - Treatment and Management Issues
Cavan	Baileborough	0200PUB0102	7785	2580	Upgrade of water treatment plant	December 2021									Y
Cavan	Belturbet	0200PUB0108	1926	492	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction required compliance by December 2020. Monitoring underway to verify effectiveness of the action programme.					Y				
Cavan	Shercock	0200PUB0116	712	217	To be confirmed - relates to private Group Water Scheme (not the responsibility of Irish Water)	Upgrade works at the treatment plant (which is operated under a private Group Water Scheme) have been approved, but no completion date provided.							Y		
Cavan	Dowra PWS	0200PUB0111	92	28	To be confirmed - relates to private Group Water Scheme (not the responsibility of Irish Water)	Upgrade works at the treatment plant (which is operated under a private Group Water Scheme) have been approved, but no completion date provided.							Y		
Clare	Corofin	0300PUB1010	1,276	302	Upgrade of water treatment plant	June 2022							Y		Y
Clare	Ennistymon RWS	0300PUB1004	6,961	6,062	Upgrade of water treatment plant	March 2023									Y
Clare	West Clare RWS (New WTP)	0300PUB1066	11,236	11,017	Upgrade of water treatment plant	EPA Direction requires compliance by December 2021				Y					
Cork	Glashaboy	0500PUB3303	22,808	20,010	To be submitted by Irish Water	To be submitted by Irish Water									Y
Cork	Glengarriff	0500PUB4208	353	341	Upgrade of water treatment plant	September 2021	Y			Y					
Cork	Leap	0500PUB4604	497	318	Abandon source and connect to Skibbereen water treatment plant	March 2021				Y					
Cork	Schull	0500PUB4503	946	547	Abandon source and connect to Skibbereen water treatment plant	March 2021				Y					
Cork City	Cork City Water Supply	0400PUB1001	87,114	42,733	Upgrade of water treatment plant	December 2021									Y
Donegal	Ballymagroarty	0600PUB1132	756	665	Installation of GAC filtration	To be submitted by Irish Water				Y					
Donegal	Glenties-Ardara	0600PUB1070	3,536	1,754	Installation of chloramination at water treatment plant	To be submitted by Irish Water				Y					
Dun Laoghaire Rathdown	Roundwood	1000PUB1006	42,106	7,263	Upgrade of Vartry Water Treatment Plant	July 2021				Y					Y
Fingal	Leixlip	0900PUB1001	590,167	180,000	Installation of UV disinfection at Leixlip 'old plant'	March 2021						Y			Y
Kerry	Ballyheigue	1300PUB1001	2,466	2,842	Installation of UV disinfection	September 2021	Y								
Kerry	Cahersiveen	1300PUB1050	1,370	1,141	To be submitted by Irish Water	To be submitted by Irish Water	Y			Y					
Kerry	Caragh Lake	1300PUB1046	1,899	720	Upgrade of pressure filtration	To be submitted by Irish Water									Y
Kerry	Mountain Stage	1300PUB1119	840	780	Upgrade of treatment plant to include filtration plus coagulation and/or UV.	January 2021	Y								

Kilkenny	Kilkenny City (Radestown) WS	1500PUB1010	14,441	4,597	Abandon source of water supply and replace with Troyswood PWS	EPA Direction requires compliance by June 2022				Y					
Kilkenny	Piltown-Fiddown	1500PUB1013	2,955	1,015	Develop new groundwater source	December 2022	Y								
Laois	Abbeyleix 1 PWS	1600PUB1056	1,836	864	Installation of pressure filtration & UV disinfection	September 2021	Y								
Limerick	Foynes/Shannon Estuary PWS	1900PUB1027	7,023	20,818	To be submitted by Irish Water	To be submitted by Irish Water					Y				
Limerick	Fedamore	1900PUB1048	492	212	Develop new groundwater source	June 2021								Y	Y
Limerick	Newcastle West	1900PUB1042	9,448	3,266	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction required compliance by June 2020. Monitoring underway to verify effectiveness of the action programme.					Y				
Longford	Gowna	2000PUB1011	4,359	1,856	Improve operations at the water treatment plant to include optimisation of coagulant dosing	March 2021				Y					
Longford	Granard	2000PUB1006	2,598	1,414	Improve operations at the water treatment plant to include optimisation of coagulant dosing	March 2021				Y					
Longford	Longford Central	2000PUB1010	16,729	6,939	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides.	EPA Direction required compliance by December 2019. Monitoring underway to verify effectiveness of the action programme.					Y				
Louth	Greenmount	2100PUB1002	4,814	1,102	To be submitted by Irish Water	To be submitted by Irish Water									Y
Louth	Tallanstown	2100PUB1005	1,978	447	Replacement of supply with Cavanhill PWS	June 2022								Y	Y
Mayo	Newport PWS	2200PUB1022	684	276	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction requires compliance by December 2021					Y				
Meath	Drumcondrath	2300PUB1005	1,182	589	Develop new groundwater sources or install coagulation, flocculation & clarification at water treatment plant	June 2023				Y					
Meath	Navan & MidMeath PWS	2300PUB1016	38,985	11,361	Upgrade of water treatment plant	January 2021									Y
Offaly	Clara/Ferbane RWSS	2500PUB1003	7,467	2,502	To be submitted by Irish Water	To be submitted by Irish Water				Y					
Tipperary	Clonmel Poulavanogue	2900PUB0109	2,596	1,840	To be submitted by Irish Water	To be submitted by Irish Water	Y								
Tipperary	Galtee Regional	2900PUB0130	11,436	8,095	Upgrade of coagulation control at water treatment plant	June 2021								Y	Y Y
Waterford	Dungarvan	3100PUB1039	11,472	5,958	Upgrade of water treatment plant - install run to waste facility, turbidity monitors on each borehole, flow meters & level probes	June 2021								Y	
Wexford	Clonroche	3300PUB1452	522	254	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction required compliance by January 2021. Monitoring underway to verify the effectiveness of the action programme.					Y				
Wicklow	Aughrim / Annacurra	3400PUB1023	1,594	381	Abandon source and connect to Arklow water treatment plant	December 2023				Y					
Wicklow	Enniskerry Public Supply	3400PUB1019	2,667	856	Upgrade of Vartry Water Treatment Plant	July 2021				Y					Y

Wicklow	Wicklow Regional Public Supply	3400PUB1005	15,598	4,495	Upgrade of Vartry Water Treatment Plant	July 2021				Y					Y
Wicklow	Bray	3400PUB1001	28,934	7,945	Upgrade of Vartry Water Treatment Plant	July 2021				Y					Y
Wicklow	Greystones/Windgates/Templecarraig	3400PUB1003	16,380	4,204	Upgrade of Vartry Water Treatment Plant	July 2021				Y					Y
Wicklow	Kilmacanogue	3400PUB1009	1,237	332	Upgrade of Vartry Water Treatment Plant	July 2021				Y					Y
Wicklow	Newtown Newcastle Kilcoole	3400PUB1010	12,724	3,273	Upgrade of Vartry Water Treatment Plant	July 2021				Y					Y