

# Site Visit Report

Under the *European Union (Drinking Water) Regulations 2023*, the Environmental Protection Agency (EPA) is the supervisory authority in relation to Uisce Éireann and its role in the provision of public drinking water supplies. This audit was carried out to assess the performance of Uisce Éireann in providing clean and wholesome water to the public water supply named below.

The audit process is a sample of the performance of a water treatment plant and public water supply on a given date.

| Water Supply Zone        |                 |
|--------------------------|-----------------|
| Name of Installation     | Crossmolina PWS |
| Organisation             | Uisce Éireann   |
| Scheme Code              | 2200PUB1013     |
| County                   | Mayo            |
| Site Visit Reference No. | SV30719         |

| Report Detail |                |
|---------------|----------------|
| Issue Date    | 19/12/2024     |
| Prepared By   | Jennifer Brady |

| Site Visit Detail   |  |           |       |
|---------------------|--|-----------|-------|
| Date Of Inspection  | 05/12/2024   | Announced | No    |
| Time In             | 11:00  | Time Out  | 11:45 |
| EPA Inspector(s)    | Jennifer Brady   |           |       |
| Additional Visitors | N/A  |           |       |
| Company Personnel   | Uisce Éireann: Brian Conmy, Siobhan Sheridan<br>Mayo County Council (working in partnership with Uisce Éireann): Catherine Hangan, Eddie Munnely & Sean Keane. |           |       |

## > Summary of Key Findings

1. Disinfection consists of Chlorination only.
2. Network chlorine residuals are monitored in the Crossmolina water supply once per week. A suitable monitoring frequency (a minimum of 2-3 times per week) is recommended to verify that there is a minimum chlorine residual of 0.1 mg/l throughout the network to ensure that consumers are receiving adequately disinfected water.

## > Introduction

The Crossmolina Public Water Supply (PWS) produces approximately 650 m<sup>3</sup>/hour serving a population of 1,153. Raw water is abstracted from a spring located approximately 1km from the water treatment plant (WTP). Treatment consists of disinfection via chlorination and treated water is stored at an on-site reservoir.

## > Supply Zones Areas Inspected

This audit assessed the chlorination disinfection system at the Crossmolina Water Treatment Plant.



## 1. Disinfection Audits 2024

|     | Answer   |
|-----|--|
| 1.1 | Is chlorination used for primary disinfection? |
|     | Yes  |

|   | Answer  |
|---|---|
| 1.2   | Did Uisce Éireann confirm the type of chlorine disinfectant in use? |
|   | Yes   |
| <b>Comment</b>  |   |
| Uisce Éireann confirmed that the chlorine disinfectant in use is 10% Sodium Hypochlorite. |   |

|   | Answer   |
|---|--|
| 1.3   | Are there duty and standby chlorine dosing pumps in place? |
|   | Yes  |
| <b>Comment</b>  |  |
| Uisce Éireann confirmed there is regular switch over between duty/standby pumps every 24 hours. |  |

|  | Answer   |
|--|--|
| 1.4  | Is there automatic switchover in the event of failure of one of the chlorine dosing pumps? |
|  | Yes  |
| <b>Comment</b>   |  |
| Uisce Éireann confirmed that the automatic changeover facility is regularly checked to ensure it is working efficiently. |  |

|     | Answer   |
|-----|--|
| 1.5 | Is the chlorine dosing rate flow proportional? |
|     | Yes  |

|     | Answer  |
|-----|---|
| 1.6 | Is there a continuous residual chlorine monitor, with alarm, to verify chlorine dosing is taking place at the target level? |
|     | Yes   |

|  | Answer |
|--|--------|
|--|--------|

|   |   |     |
|---|---|-----|
| 1.7   | Is there a continuous residual chlorine monitor, with alarm, at a suitable sample location after contact time has been completed? | Yes |
| <b>Comment</b>  |   |     |
| Uisce Éireann confirmed that there is two monitors present one on the inlet and a second on the outlet. |   |     |

|   |   |               |
|---|---|---------------|
|   |   | <b>Answer</b> |
| 1.8   | Can data trends from the online residual monitor be viewed on site? | Yes           |
| <b>Comment</b>  |   |               |
| Trends were available on site to view on HMI/SCADA and it was confirmed by Uisce Éireann that trends can also be viewed remotely so operators have access to the data to monitor the trends off site. |   |               |

|   |  |               |
|---|--|---------------|
|   |  | <b>Answer</b> |
| 1.9   | Are there low and high chlorine alarm settings on each chlorine monitor? | Yes           |
| <b>Comment</b>  |  |               |
| The low and high chlorine alarm settings of each chlorine monitor are outlined in the alarm response procedure. |  |               |
| There is two chlorine monitors on site.   |  |               |
| Chlorine Alarm CL001: Low (0.4) High (1.5) Delay Time: 300 seconds  |  |               |
| Chlorine Alarm CL002: Low (0.5) High (1.2) Delay Time: 300 seconds  |  |               |

|   |   |               |
|---|---|---------------|
|   |   | <b>Answer</b> |
| 1.10  | Is there a documented alarm response procedure for responding to chlorine alarms? | Yes           |
| <b>Comment</b>  |   |               |
| There is a documented alarm procedure in place containing the alarm setpoints and procedure. The alarms are triggered by a text alert message which is sent to the Primary Caretaker, Relief Caretaker and Environmental Technician and contact is made between the text message recipients to ensure the incident is responded to. |   |               |

|                |   |               |
|----------------|---|---------------|
|                |   | <b>Answer</b> |
| 1.11           | Have staff been trained on the chlorine alarm response procedure? | Yes           |
| <b>Comment</b> |   |               |

Training has been provided to all staff on the response procedure and Uisce Éireann ensured that training records are available.

|   |  | Answer |
|---|--|--------|
| 1.12  | Are chlorine alarms dialled out via a cascade system to allow a timely response by plant operators?  | Yes    |
| <b>Comment</b>  |  |        |
| 2 personnel receive the alarms. The alarm is sent to the first individual and if un-responsive, the alarm cascades to the second individual.              |  |        |
|   |  | Answer |
| 1.13  | Is there automatic shutdown of the supply in the event of the chlorine level dropping below the low level or rising above the high chlorine alarm setting? | Yes    |
|   |  | Answer |
| 1.14  | Are service due / monitoring instrument calibration dates for the chlorine monitors within date?   | Yes    |
| <b>Comment</b>  |  |        |
| Both chlorine monitors were last serviced/calibrated on the 04/12/2024 and the next service/calibration due was the 04/06/2025.                           |  |        |
|   |  | Answer |
| 1.15  | Is the site specific target contact time being achieved?   | Yes    |
| <b>Comment</b>  |  |        |
| The Total Effective Ct after (t) 46.13 minutes exceeds the Target Ct of 19.80 mg.min/l therefore the site specific target contact time is being achieved. |  |        |
|   |  | Answer |
| 1.16  | Is the minimum effective contact time of 15 mg. min/l being achieved?  | Yes    |
| <b>Comment</b>  |  |        |
| Uisce Éireann confirmed a minimum effective contact time of 20.76 mg.min/l was being achieved.  |  |        |

|   |  | Answer |
|---|--|--------|
| 1.17  | Is the residual chlorine level $\geq$ 0.1 mg/l at the extremity of the distribution network? | Yes    |
| <b>Comment</b>  |  |        |
| <p>Uisce Éireann confirmed monitoring locations showing the extent of the network. A total of 12 monitoring locations can be observed on a monthly schedule. All monitoring locations observed on the day of the audit for monitoring in November 2024 were <math>&gt;</math> 0.1 mg/l.</p> |  |        |

|   |   | Answer |
|---|---|--------|
| 1.18  | Is monitoring of network residual chlorine undertaken several times per week? | No     |
| <b>Comment</b>  |   |        |
| <p>Network chlorine residuals are monitored in the Crossmolina water supply at two locations (Moylew and Benjary) every day, however the monitoring frequency at other locations in the network is sporadic. A suitable monitoring frequency (a minimum of every 2-3 days) is recommended to verify that there is a minimum chlorine residual of 0.1 mg throughout the network including the extremities to ensure that consumers are receiving adequately disinfected water.</p> |   |        |

## Recommendations

| Subject     | Crossmolina Disinfection Audit 2024  | Due Date | 24/01/2025 |
|-------------|--|----------|------------|
| Action Text | <p><b>Uisce Éireann is responsible for ensuring a clean and wholesome supply of drinking water and should implement the following recommendations without delay.</b></p> <p>1. Network Monitoring: Ensure the monitoring of residual chlorine is undertaken several (two to three) times per week at different points of the network to include network extremities.</p> <p>Network chlorine residuals are monitored in the Crossmolina water supply at two locations (Moyle and Benjary) every day, however the monitoring frequency at other locations in the network is sporadic. Other network chlorine residuals are monitored in the Crossmolina water supply once per week. A suitable monitoring frequency (a minimum of 2-3 times per week) is recommended to verify that there is a minimum chlorine residual of 0.1 mg/l throughout the network to ensure that consumers are receiving adequately disinfected water.</p> <p><b>Actions required by Uisce Éireann</b></p> <p>During the audit, Uisce Éireann representatives were advised of the audit findings and that action must be taken by Uisce Éireann to address the issues raised.</p> <p>Uisce Éireann should submit a report to the EPA on or before [24/01/2025] detailing the actions taken and planned, with timescales, to close out the above recommendations.</p> <p>The EPA advises that the findings and recommendations from this audit report should, where relevant, be addressed at other public water supplies.</p> |          |            |