

Site Visit Report

Under the European Union (Drinking Water) Regulations 2014 as amended, the Environmental Protection Agency is the supervisory authority in relation to Irish Water and its role in the provision of public water supplies. This Audit was carried out to assess the performance of Irish Water in providing clean and wholesome water to the visited public supply.

The audit process is a sample on a given date of the facility's operation. Where a finding against a particular issue has been reported this should not be construed to mean that this issue is fully addressed.

Water Supply Zone	
Name of Installation	Carrickmacross
Organisation	Irish Water
Scheme Code	2400PUB1005
County	Monaghan
Site Visit Reference No.	SV25554

Report Detail	
Issue Date	10/06/2022
Prepared By	Criona Doyle

Site Visit Detail			
Date Of Inspection	20/05/2022	Announced	Yes
Time In	10:38	Time Out	11:32
EPA Inspector(s)	Criona Doyle		
Additional Visitors	Lorcan Farrell; Patricia Mallen; Denise McElvaney.		
Company Personnel	Irish Water: Yvonne McMonagle. Veolia (acting under DBO contract to Irish Water): Robert McCann; Aaron Murray; Sean Cronin.		

> Summary of Key Findings

- (1) Disinfection consists of chlorination and ultraviolet (UV) treatment. The audit found that the disinfection system was operating satisfactorily during the inspection.
- (2) There is no facility to switch over to a standby UV unit as only a single duty UV unit is provided. There is no documented procedure for responding to the chlorine and UV disinfection alarms. A copy of the validation cert for the UV unit was not available at the audit.
- (3) Monitoring of residual chlorine should include the network extremities.

> Introduction

The Carrickmacross Public Water Supply (PWS) produces approximately 1,236m³/d of water serving a population of 5,293 (EDEN figures). The audit focused on the disinfection system at the Carrickmacross WTP. This site was not surveyed or upgraded under Irish Water's Disinfection Programme.

> Supply Zones Areas Inspected

This audit assessed the chlorination and UV disinfection system at the Carrickmacross WTP.



1. Disinfection Programme Audits 2022

		Answer
1.1	Is chlorination used for primary disinfection?	No
		Answer
1.2	Can you establish what type of chlorine disinfectant is used?	Yes
		Answer
1.3	Are there duty and standby chlorine dosing pumps in place?	Yes
		Answer
1.4	Is there automatic switchover in the event of failure of one of the chlorine dosing pumps?	Yes
		Answer
1.5	Is the chlorine dosing rate flow proportional?	Yes
		Answer
1.6	Is the chlorine dosing rate fixed?	Not Applicable
		Answer
1.7	Can IW / LA confirm the target residual chlorine level for the final water leaving the plant?	Yes
		Answer
1.8	Is there a continuous residual chlorine monitor on the final water?	Yes
		Answer
1.9	Can data trends from the online residual monitor be viewed on site?	Yes
		Answer
1.10	Are there low and high chlorine alarm settings?	Yes

		Answer
1.11	Is there an alarm response procedure available on site for responding to chlorine alarms?	No
	Comment	
	There is no documented alarm response procedure for responding to chlorine alarms.	
		Answer
1.12	Is there automatic shutdown of the supply in the event of the chlorine level dropping below the low chlorine alarm setting or rising above the high chlorine alarm setting?	Yes
		Answer
1.13	Are service due / monitoring instrument calibration dates for the chlorine monitors within date?	Yes
		Answer
1.14	Is the site specific contact time being achieved ? If answer is NO, proceed to question 15	Not Applicable
		Answer
1.15	Is the minimum effective contact time of 15 mg. min/l being achieved?	Not Applicable
		Answer
1.16	Is the residual chlorine level ≥ 0.1 mg/l at the extremity of the distribution network?	Yes
	Comment	
	Monitoring of residual chlorine levels is taking place at a number of locations several times per week but the monitoring locations are not close to the extremities of the network.	
		Answer
1.17	Is UV treatment used for primary disinfection?	Yes

		Answer
1.18	Are there duty and standby UV units in operation?	No
	Comment	
	There is one UV unit on site (duty unit).	

		Answer
1.19	Is there automatic switchover between the duty and standby UV units in the event of failure of the duty unit?	No
	Comment	
	There is no standby UV unit on site.	

		Answer
1.20	Is there automatic plant shutdown in the event of UV units failing or operating outside of their validated range?	Yes

		Answer
1.21	Is there continuous monitoring of the UV units to verify operation within validation range at all times?	Yes

		Answer
1.22	Can data trends from the online UV monitor(s) be viewed on-site?	Yes

		Answer
1.23	Is there an alarm response procedure available on site for responding to UV alarms ?	No
	Comment	
	There is no documented alarm response procedure for responding to UV alarms.	

		Answer
1.24	Are service due / monitoring instrument calibration dates for the UV units within date?	Yes

		Answer
1.25	Is a copy of the validation certificate for the UV disinfection system available on site ?	No
Comment		
A copy of the UV validation certification was not available on site.		

		Answer
1.26	Is there a plate on the UV unit with the validation criteria?	Yes

		Answer
1.27	Did IW confirm that the UV units are operating within the validation range?	Yes

		Answer
1.28	Have all relevant staff received training on the disinfection upgrades?	Not Applicable
Comment		
Not applicable as upgrade works have not been undertaken.		



2. Site Specific Issues

	Answer
2.1 Have staff been trained on the UV disinfection system?	No
Comment	
Operational staff reported that training has not been provided on the UV disinfection system.	

Recommendations

Subject	Carrickmacross- Disinfection Audit	Due Date	11/07/2022
Action Text	<p>Recommendations</p> <p>Irish Water is responsible for ensuring a safe and secure supply of drinking water. To address these issues, Irish Water should implement the following recommendations without delay.</p> <ol style="list-style-type: none">1. Irish Water should ensure that monitoring of residual chlorine is undertaken several times a week at different points of the network to include the network extremities.2. Irish Water should ensure that there are duty and standby UV disinfection units with automatic changeover or plant shutdown in the event of failure of one of the UV disinfection units.3. Irish Water should ensure that a copy of the validation certificate is maintained demonstrating that the UV unit is validated to an appropriate international validation standard.4. Irish Water should ensure that (a) there is a documented alarm response procedure and (b) ensure that all staff are trained on the alarm response for UV and chlorine alarms. <p>Follow-Up Actions required by Irish Water</p> <p>During the audit, Irish Water representatives were advised of the audit findings and that action must be taken as a priority by Irish Water to address the issues raised.</p> <p>This report has been reviewed and approved by Regina Campbell, Drinking Water Team Leader.</p> <p>Irish Water should submit a report to the Agency on or before 11/07/22 detailing how it has dealt with the issues of concern identified during this audit.</p> <p>The report should include details on the action taken and planned to address the various recommendations, including time frame for commencement and completion of any planned work.</p> <p>The EPA also advises that the findings and recommendations from this audit report should, where relevant, be addressed at all other treatment plants operated and managed by Irish Water.</p> <p>Please quote the Compliance Plan DW20220052 in any future correspondence in relation to this Report.</p>		