

Site Visit Report

Under the European Union (Drinking Water) Regulations 2014 as amended, the Environmental Protection Agency is the supervisory authority in relation to Irish Water and its role in the provision of public water supplies. This Audit was carried out to assess the performance of Irish Water in providing clean and wholesome water to the visited public supply.

The audit process is a sample on a given date of the facility's operation. Where a finding against a particular issue has been reported this should not be construed to mean that this issue is fully addressed.

| Water Supply Zone | |
|---------------------------------|-------------|
| Name of Installation | Bunclody |
| Organisation | Irish Water |
| Scheme Code | 3300PUB1425 |
| County | Wexford |
| Site Visit Reference No. | SV25676 |

| Report Detail | |
|--------------------|----------------|
| Issue Date | 15/07/2022 |
| Prepared By | Joanne Creedon |

| Site Visit Detail | | | |
|----------------------------|---|------------------|-------|
| Date Of Inspection | 04/07/2022 | Announced | Yes |
| Time In | 12:05 | Time Out | 13:05 |
| EPA Inspector(s) | Joanne Creedon | | |
| Additional Visitors | | | |
| Company Personnel | Irish Water: Samantha Keane Wexford County Council (under service level agreement to Irish Water): Michael Murphy, John Breen, Enda Flynn. | | |

> Summary of Key Findings

(1) Disinfection consists of chlorination and ultraviolet (UV) treatment. The disinfection system was operating satisfactorily during the inspection.

(2) Automatic shutdown occurs only in the case of high and low UV alarms and not in the case of high and low chlorine alarms.

> Introduction

The Bunclody (Carrickduff) Public Water Supply (PWS) produces approximately 688m³/d of water serving a population of 2,129 (EDEN figures). The audit focused on the disinfection system at the Bunclody (Carrickduff) Water Treatment Plant (WTP). The site has been assessed under Irish Water's Disinfection Programme and reported to the EPA as having been fully commissioned and available on telemetry on 31/07/2019.

> Supply Zones Areas Inspected

This audit assessed the ultraviolet (UV) and chlorination disinfection systems at the Bunclody (Carrickduff) WTP.



1. Disinfection Programme Audits 2022

| | | |
|-----|---|----------------|
| | | Answer |
| 1.1 | Is chlorination used for primary disinfection? | No |
| | Comment | |
| | UV is used for primary disinfection. Chlorination is secondary. | |
| | | Answer |
| 1.2 | Did Irish Water confirm the type of chlorine disinfectant in use? | Yes |
| | | Answer |
| 1.3 | Are there duty and standby chlorine dosing pumps in place? | Yes |
| | | Answer |
| 1.4 | Is there automatic switchover in the event of failure of one of the chlorine dosing pumps? | Yes |
| | | Answer |
| 1.5 | Is the chlorine dosing rate flow proportional? | Yes |
| | | Answer |
| 1.6 | Is the chlorine dosing rate fixed? | Not Applicable |
| | | Answer |
| 1.7 | Can IW / LA confirm the target residual chlorine level for the final water leaving the plant? | Yes |
| | | Answer |
| 1.8 | Is there a continuous residual chlorine monitor on the final water? | Yes |
| | | Answer |
| 1.9 | Can data trends from the online residual monitor be viewed on site? | Yes |

| | | |
|------|--|---------------|
| | | Answer |
| 1.10 | Are there low and high chlorine alarm settings? | Yes |
| | | Answer |
| 1.11 | Is there an alarm response procedure available on site for responding to chlorine alarms? | Yes |
| | | Answer |
| 1.12 | Is there automatic shutdown of the supply in the event of the chlorine level dropping below the low chlorine alarm setting or rising above the high chlorine alarm setting? | No |
| | Comment | |
| | No automatic plant shutdown in the event of the chlorine level dropping below the low chlorine alarm setting or rising above the high chlorine alarm setting. Chlorination is secondary disinfection and UV is primary disinfection. UV has automatic shutdown in the event of failure and this shuts down the chlorination as well. | |
| | | Answer |
| 1.13 | Are service due / monitoring instrument calibration dates for the chlorine monitors within date? | Yes |
| | | Answer |
| 1.14 | Is the site specific contact time being achieved? | Yes |
| | | Answer |
| 1.15 | Is the minimum effective contact time of 15 mg. min/l being achieved? | Yes |
| | | Answer |
| 1.16 | Is the residual chlorine level \geq 0.1 mg/l at the extremity of the distribution network? | Yes |
| | | Answer |
| 1.17 | Is UV treatment used for primary disinfection? | Yes |

| | | |
|------|---|---------------|
| | | Answer |
| 1.18 | Are there duty and standby UV units in operation? | Yes |
| | | Answer |
| 1.19 | Is there automatic switchover between the duty and standby UV units in the event of failure of the duty unit? | Yes |
| | | Answer |
| 1.20 | Is there automatic plant shutdown in the event of UV units failing or operating outside of their validated range? | Yes |
| | | Answer |
| 1.21 | Is there continuous monitoring of the UV units to verify operation within validation range at all times? | Yes |
| | | Answer |
| 1.22 | Can data trends from the online UV monitor(s) be viewed on-site? | Yes |
| | | Answer |
| 1.23 | Is there an alarm response procedure available on site for responding to UV alarms ? | Yes |
| | | Answer |
| 1.24 | Are service due / monitoring instrument calibration dates for the UV units within date? | Yes |
| | | Answer |
| 1.25 | Is a copy of the validation certificate for the UV disinfection system available on site ? | Yes |
| | | Answer |
| 1.26 | Is there a plate on the UV unit with the validation criteria? | Yes |

| | Answer |
|---|---------------|
| 1.27 Did IW confirm that the UV units are operating within the validation range? | Yes |

| | Answer |
|---|---------------|
| 1.28 Have all relevant staff received training on the disinfection upgrades? | Yes |

Recommendations

| | | | |
|--------------------|---|-----------------|------------|
| Subject | Bunclody - Disinfection Audit | Due Date | 15/08/2022 |
| Action Text | <p>Recommendation(s)</p> <p>Irish Water is responsible for ensuring a safe and secure supply of drinking water. To address these issues, Irish Water should implement the following recommendation(s) without delay.</p> <ol style="list-style-type: none">1. Irish Water should install automatic shutdown of the plant linked to the low and high residual chlorine alarm settings. <p>Follow-Up Actions required by Irish Water</p> <p>During the audit, Irish Water representatives were advised of the audit findings and that action must be taken as a priority by Irish Water to address the issues raised.</p> <p>This report has been reviewed and approved by Michelle Minihan, Drinking Water Team Leader.</p> <p>Irish Water should submit a report to the Agency on or before 15/08/2022 detailing how it has dealt with the issues of concern identified during this audit.</p> <p>The report should include details on the action taken and planned to address the various recommendations, including time frame for commencement and completion of any planned work.</p> <p>The EPA also advises that the findings and recommendations from this audit report should, where relevant, be addressed at all other treatment plants operated and managed by Irish Water.</p> <p>Please quote the Action Reference Number DW20220075 in any future correspondence in relation to this Report.</p> | | |